AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 12-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	12-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 7 Days Compressive Strength
Date of Test	19-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Testing	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	456	22.0	21.60
2	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	466	22.3	
3	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	463	20.5	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Division
Bangalore

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 12-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	12-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 7 Days Compressive Strength
Date of Test	19-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	463	21.36	21.42
2	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	473	22.54	
3	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	470	20.36	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk Zn)
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪವಿಭಾಗ

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 20-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	13-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 7 Days Compressive Strength
Date of Test	20-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	470	22.36	22.87
2	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	480	22.56	
3	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	473	23.68	

Remarks :

AARTN ASSOCIATES BANGALORE

AE-2

Asst. Executive Engineer
Yelahanka Sub. Divisi
(BBMP Ynk Zn.)
Yelahanka, Bangal

J-73.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರ
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ.

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 20-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	13-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 7 Days Compressive Strength
Date of Test	20-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	460	22.54	22.72
2	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	471	22.63	
3	C.C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	457	22.98	

Remarks :

AARTN ASSOCIATES DATE BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Division

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 20-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	13-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 7 Days Compressive Strength
Date of Test	20-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Testing	Dimension of Specification	Cross sectional area	Maximum Load in K.N	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	467	22.36	21.43
2	C C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	477	21.56	
3	C C Road	M30	13-05-2022	20-05-2022	150x150x150	22500	464	20.36	

Remarks :

AARTN ASSOCIATES BANGALORE DATE

AE-02

Asst. Executive Engineer
Yelahanka Sub Division
(BBMP Ynk Zn)
Yelahanka Bengalore

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-106

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 12-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	12-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 28 Days Compressive Strength
Date of Test	09-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	695	31.9	31.45
2	C C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	705	31.3	
3	C C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	698	31.3	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub Division
(BBMP Ynk Zn)
Yelahanka, Bangalore

AE-02

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರ
ಯಲಹಂಕ ಉಪವಿಭಾಗ.

AARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 09-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	12-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 28 Days Compressive Strength
Date of Test	09-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Weight of the sample	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	kg	KN	N/mm²	N/mm²
1	C.C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	8.92	692	31.3	32.27
2	C.C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	9.07	703	32.0	
3	C.C Road	M30	12-05-2022	09-06-2022	150x150x150	22500	9.13	689	33.6	

Remarks :

AARTN ASSOCIATES BANGALORE DATE

Asst. Executive Engineer
Yelahanka Sub. Division
BBMP Ynk. Zone
Bangalore

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಯಲಹಂಕ ಉಪವಿಭಾಗ ಉಪವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ, ಬೆಂಗಳೂರು-106

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 10-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zono, Bengaluru.
Contractor	Srl. Gopl Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	13-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 28 Days Compressive Strength
Date of Test	10-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Weight of the sample	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	kg	KN	N/mm²	N/mm²
1	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.72	682	32.58	32.08
2	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.87	695	31.89	
3	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.62	686	31.78	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zone)
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪವಿಭಾಗ ಉಪವಿಭಾಗ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ, ಬೆಂಗಳೂರು-106

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)	Date: 16-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	9-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 7 Days Compressive Strength
Date of Test	16-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	9-05-2022	16-05-2022	150x150x150	22500	466	8.25	7.58
2	C.C Road	DLC(1:5:10)	9-05-2022	16-05-2022	150x150x150	22500	476	6.25	
3	C.C Road	DLC(1:5:10)	9-05-2022	16-05-2022	150x150x150	22500	463	8.25	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub Division
(BBMP Ynk Zn)
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-63

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 16-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	09-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 7 Days Compressive Strength
Date of Test	16-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	09-05-2022	16-05-2022	150x150x150	22500	473	7.68	7.97
2	C.C Road	DLC(1:5:10)	09-05-2022	16-05-2022	150x150x150	22500	483	8.25	
3	C.C Road	DLC(1:5:10)	09-05-2022	16-05-2022	150x150x150	22500	476	7.98	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub Division

AE-02

AE-03

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-10

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 18-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	11-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 7 Days Compressive Strength
Date of Test	18-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	453	7.5	7.60
2	C C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	472	7.98	
3	C C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	460	7.32	

Remarks :

AARTN ASSOCIATES DATE BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

RARTN ASSOCIATES

The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 18-05-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	11-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 7 Days Compressive Strength
Date of Test	18-05-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	468	7.25	7.64
2	C.C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	466	8.01	
3	C.C Road	DLC(1:5:10)	11-05-2022	18-05-2022	150x150x150	22500	471	7.65	

Remarks :

ARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 06-0-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, konchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	09-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	06-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	696	12.3	11.62
2	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	707	11.3	
3	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	693	11.4	

Remarks :

AARTN ASSOCIATES DATE BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Div
(BBMP Ynk. Zn
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-106

AARTN ASSOCIATES
The Modern Construction Solutions

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)

Date: 06-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	09-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	06-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	699	11.2	11.64
2	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	689	11.7	
3	C.C Road	DLC(1:5:10)	09-05-2022	06-06-2022	150x150x150	22500	705	12.0	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub Division
(BBMP Ynk Zn)
Yelahanka, Bangalore

AE-02

ARTN ASSOCIATES
he Modern Construction Solutions

1059, MIG-A Sector, Opp. Railwheel Factory,
elahanka New Town, Bangalore - 64
h : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 07-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	10-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	07-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Testing	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	700	11.4	11.70
2	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	694	12.4	
3	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	697	11.4	

Remarks :

ARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯ ಪಾಲಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ, ಬೆಂಗಳೂರು-೫೬

AARTN ASSOCIATES
The Modern Construction Solutions

1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
: 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 08-06-2022

Name of Work :"Augmental of water supply through boweli, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	11-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	08-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	702	11.5	11.69
2	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	695	11.7	
3	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	699	12.0	

Remarks :

AARTN ASSOCIATES BANGALORE

W-03 AE

AE W-02

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ.
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-10

AARTN ASSOCIATES
The Modern Construction Solutions

1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph: 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) — Date: 08-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaloro Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	11-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	08-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Testing	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	711	11.5	11.40
2	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	704	11.0	
3	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	708	11.7	

Remarks :

AARTN ASSOCIATES BANGALORE

Asst. Executive Engineer
Yelahanka Sub. Divis...
(BBMP Ynk. Zn)
Yelahanka, Bangalore

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ,
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-106

AARTN ASSOCIATES
The Modern Construction Solutions

1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 08-06-2022

Name of Work :"Augmental of water supply through bowell, network of pipelines and ground water recharge facilitiea in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Reciept	11-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	08-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Testing	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm²	N/mm²
1	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	716	11.3	11.22
2	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	709	11.40	
3	C.C Road	DLC(1:5:10)	11-05-2022	08-06-2022	150x150x150	22500	713	11.02	

Remarks :

AARTN ASSOCIATES

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

W.03. AE